

Fiscal Services
1800 Ignacio Blvd
Novato CA 94949
415-884-3162

PROJECT: KENTFIELD – PARKING LOT IMPROVEMENTS PROJECT #16-0407

ADDENDUM #2

Marin Community College District

May 2, 2016

REVISIONS/CLARIFICATIONS

None

BID QUESTIONS

BQ #1 With reference to Addendum #1, Revision/Clarification e. Sandblasting, is “grinding” an acceptable method?

Answer: “Grinding” is also an acceptable method to remove existing paint in order to reduce/eliminate ghosting in the seal coats.

BQ #2 Please clarify “crack fill” parameters.

Answer: “Crack fill” is expected to be used for longitudinal, transverse & block cracking between 0.12 & 1.00 inch.

END OF ADDENDUM #2